

# CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI  
MAYOR

BOARD OF  
**BUILDING AND SAFETY**  
COMMISSIONERS

VAN AMBATIELOS  
PRESIDENT

JAVIER NUNEZ  
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL  
GEORGE HOVAGUIMIAN  
ELVIN W. MOON

DEPARTMENT OF  
**BUILDING AND SAFETY**  
201 NORTH FIGUEROA STREET  
LOS ANGELES, CA 90012

**OSAMA YOUNAN, P.E.**  
GENERAL MANAGER  
SUPERINTENDENT OF BUILDING

**JOHN WEIGHT**  
EXECUTIVE OFFICER

ITW POLYMERS SEALANTS North America, INC.  
12271 Monarch Street  
Garden Grove, CA 92841

Attn: Lesley Henry III  
(714) 793-1974

RESEARCH REPORT: RR 24208  
(CSI #07 18 13)

Expires: October 1, 2023  
Issued Date: September 14, 2021  
Code: 2020 LABC

**GENERAL APPROVAL** – Renewal - Elasto-Deck- 5000 Class A Roof Covering for Parking and Walking Decks.

## DETAILS

The roofing system consists of Elasto-Deck Primer, Elasto-Thane #227 (a two-component polyurethane sealant), Elasto-Deck 5001 basecoat applied at the rate of 50 square feet per gallon, yielding a thickness of 30 mils, a coat of Elasto-Glaze 6001 applied at the rate of 125 square feet per gallon, #30 silica sand spread at the rate of 50 pounds per square and Elasto-Glaze 6001 seal coat applied at the rate of 125 square feet per gallon.

**The roof system is approved for use as a Class A roof covering as required by the Code. The approval is subject to the following:**

1. The roofing components (except for the sand) shall be delivered to the job sites in sealed containers identified by the manufacturer's name and product designation.
2. Application of the components shall be onto a concrete deck in accordance with the manufacturer's instructions (a copy shall be available at the job site) consistent with the description and requirements herein. All surfaces to be coated shall be free of water, curing compounds, bond breakers, hardeners, oil, etc.

## DISCUSSION

RR 24208  
Page 1 of 2

Pacific Polymers, Incorporated

RE: Elasto-Deck- 5000 Class A Roof Covering for Parking and Walking Decks.

The report is in compliance with the 2020 City of Los Angeles Building Code.

The approval is based on tests.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction, which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternative to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.



---

QUAN NGHIEM, Chief  
Engineering Research Section  
201 N. Figueroa St., Room 880  
Los Angeles, CA 90012  
Phone - 213-202-9812  
Email – quan.nghiem@lacity.org

QN  
RR24208  
TLB2100118  
R09/14/2021  
1503.1/1505.1